

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

File No.

Dated:

It is certified that an inspection team headed by Pashupati Nath (chemist)

(Name of Officers with designation) from District Level Water Analysis Laboratory, UP Jal Nigam, Gonda (Name of Department/ Office) inspected the **S D S Public School Pachputi, Jagtapur, Mankapur, Gonda (U.P)** (Name & Address of the school) on **06/08/2026** (date of inspection) and on the basis of Water Test Report (Attached) bearing no..... date **06/08/2026**

Of District Level Water Analysis Laboratory, UP Jal Nigam, Gonda (PHED Lab) certified that the **S D S Public School Pachputi, Jagtapur, Mankapur, Gonda** (Name of school) has safe drinking Water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The above valid for a period of 1 Year.

Signature with Seal:  **Technical Manager**
Name : **Pashupati Nath** District Level Water Analysis Laboratory
Designation: **Chemist** Gonda-UPJN
Name & Address of the Office / Department:

To

S D S Public School Pachputi, Jagtapur, Mankapur, Gonda
(Name & Address of the Institution)

Note: The certificate is to be issued by the authorized officer / PHED Lab / local bodies

District Level Water Analysis Laboratory, U.P Jal Nigam (Rural), Gonda

Office of Executive Engineer, Construction division, U.P Jal Nigam, near PAC gate No-2, Gonda. Pin-271001 (Test Address only)

Test report

Sample Id:

U3086102538469589

User Information

Name:	ChandraPrakash Singh	Mobile:	9532163080
Email:	sdsps.2018@gmail.com	Pin Code:	271302
Full Address:	Village- Pachputi Jagtapur , Gram Panchayat- Pachputi Jagtapur, Block- Mankapur, District Gonda, State- Uttar Pradesh		

Sample description

Source of Sample:	S D S PUBLIC SCHOOL Ro Tap Water	Village:	Pachputi Jagtapur
Gram Panchayat:	Pachputi Jagtapur	Block:	Mankapur
District:	Gonda	State:	Uttar Pradesh
Address:		Remarks:	
Latitude:	27.0428	Longitude:	82.2145

Date & time of sample collection	Date & time of sample received in lab	Date & time of sample analysed	Date & time of report generation
04.08.2026 10:30:00 AM	04.08.2026 11:50:00 AM	06.08.2026 11:56:00 AM	06.08.2026 12:29:20 PM

Test results

S. No.	Parameter tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Method of Analysis	Remarks
1	Chloride (as Cl)*	mg/l	250	1000	18.000	Argentometric method	
2	E. coli	CFU/100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	MFT	
3	Fluoride (as F)*	mg/l	1	1.5	0.190	Ion selective electrode method	
4	Free residual Chlorine	mg/l	0.2	1	0.300	Iodometric method	
5	Iron (As Fe)*	mg/l	1	No Relaxation	0.010	Phenanthroline method or as per IS 15303:2002 Electrothermal atomic absorption/Spectrophotometer method	
6	Nitrate (as NO3)*	mg/l	45	No Relaxation	0.120	UV-Visible Spectrophotometer	
7	pH*	NA	6.5-8.5	No Relaxation	7.200	Electrometric method	
8	Sulphate (as SO4)*	mg/l	200	400	3.228	Turbidimetric method	
9	TDS*	mg/l	500	2000	96.000	Gravimetric method	
10	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	62.000	Titration method	
11	Total coliform	CFU/ 100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	MFT	
12	Total Hardness (As CaCO3)*	mg/l	200	600	50.000	EDTA Titrimetric method	
13	Turbidity*	NTU	1	5	0.680	Nephelometric method	

Note:

- 1)*Indicates parameters that are NABL accredited.
- 2) This test results related to the sample tested above
- 3) The report shall not to be reproduced in full without approval of authority
- 4) This is the end of the report

Data prepared by

Chemist: (sameer vaish)

Microbiologist: (sameer vaish)